

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No:** 7165-0082:102 Page 1 of 1

**CATEGORY:** Control Unit (Non-High Rise)

**LISTEE:** Rauland-Borg, 3450 W. Oakton St., Skokie, IL 60076  
Contact: Daryl Miceli (708) 679-0900

**DESIGN:** Model ASP3100 fire alarm control unit. Refer to listee's printed data sheet for detailed product description and operational considerations. System components:

ASP3100	Control Unit
AST3201	LCD Keypad
ASA3102	Fire Module
ASE3103	EOL Resistor
ASX3104	Power Transformer
ASV3105	Battery (2 required)

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, UL and SFM label.

**APPROVAL:** Listed as fire alarm control unit for use with separately listed compatible initiating and indicating devices.

This control unit does not generate a temporal pattern signal. If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** 1. Burglary and other non-fire function were not examined. Refer to listee's data sheet for compatible non-fire devices.

2. For Alarm verification Feature (delay of fire alarm), the Retard/reset/Restart period must be adjusted to 30 seconds or less.

**XLF:** 7165-1459:106

\*Rev. 05-25-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager